




Teletyped

7/1/74



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

TELEPHONE
AREA CODE 716 546-2700

Ginna Station
July 3, 1974



Mr. James P. O'Reilly, Director
Directorate of Regulatory Operations
Region I
U. S. Atomic Energy Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: Abnormal Occurrence 74-13: Leak in weld on Charging Pumps
discharge filter vent valve
piping
Ginna Station - Docket #50-244

Dear Mr. O'Reilly:

This is to confirm my phone call on July 3, 1974 to Mr. John Hannon to report Abnormal Occurrence 74-13 at Ginna Station.

On Wednesday, July 3, 1974 a Health Physicist noticed vapor in the charging pump room. Further investigation found the vapor to be coming from a leak in the weld that connects the 3/4" vent valve nipple to the 3" weld-o-let on the charging pump filter bypass line.

The PORC met and recommended that the plant be brought to a cold shutdown condition to make repairs. It was also recommended that the NSARS review the two 3/4" vent piping weld leaks. The unit was taken off the line at 1700 on July 3, 1974.

Very truly yours,

Charles E. Platt
Charles E. Platt
Superintendent

8304140406 740812
PDR ADOCK 05000244
S PDR

CEP:bg

cc: Mr. J. F. O'Leary, AEC
Mr. G. J. Swarthout, RG&E
Mr. L. D. White, Jr., RG&E

Handwritten: 50-244

COPY SENT REGION *I*

6186