

REE

ROCHESTER GAS AND ELECTRIC CORPORATION • 82 EAST AVENUE, ROCHESTER, N.Y. 14649

Ginna Station
May 30, 1974

TELEPHONE
AREA CODE 716 546-2700

Mr. James P. O'Reilly, Director
Directorate of Regulatory Operations
Region 1
U. S. A. E. C.
631 Park Avenue
King of Prussia, Pennsylvania 19406



Subject: Abnormal Occurrence 74-9: Failure of Underfrequency
Relay During Surveillance Test
Ginna Station
Docket 50-244

Dear Mr. O'Reilly:

This is to confirm my conversation with Mr. A. B. Davis today to report Abnormal Occurrence 74-9 at Ginna Station.

During the morning of May 30, 1974, while conducting the routine Monthly PT-9 Surveillance Test (Periodic Test - Undervoltage and Underfrequency Protection 11A and 11B - 4160 Volt Busses) one of the underfrequency relays on the 11A bus failed to transmit a signal to the logic racks when a fault condition was being simulated. This failure defeated one of the two channels of redundancy provided for underfrequency protection of this bus.

The faulty relay was replaced with a spare relay. The spare relay was tested satisfactorily and declared operable at 1125 on May 30, 1974.

Very truly yours,

Charles E. Platt

Charles E. Platt
Superintendent

CEP:bg
xct: Mr. J. F. O'Leary, AEC
Mr. G. J. Swarthout, RG&E

8304140437 740610
PDR ADOCK 05000244
S PDR

Incident 50-244

4986
COPY SENT REGION