

R

File

NEW YORK STATE

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

TELEPHONE  
AREA CODE 716 546-2700

Ginna Station  
April 26, 1974

Mr. James P. O'Reilly, Director  
Directorate of Regulatory Operations  
Region 1  
U. S. Atomic Energy Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Subject: Abnormal Occurrence 74-7: Failure of Underfrequency Relay  
During Surveillance Test  
Ginna Station  
Docket 50-244

Dear Mr. O'Reilly:

This is to confirm my conversation with Mr. Walter Baunack today to report Abnormal Occurrence 74-7 at Ginna Station.

During the morning of April 26, 1974, while conducting the routine Monthly PT-9 Surveillance Test (Periodic Test - Undervoltage and Underfrequency Protection 11A and 11B - 4160 volt Busses) one of the underfrequency relays on the 11A bus failed to transmit a signal to the logic racks when a fault condition was being simulated. This failure defeated one of the two channels of redundancy provided for underfrequency protection of this bus.

The faulty relay was replaced with a spare relay. The spare relay was tested satisfactorily and declared operable at 1430 hours on April 26, 1974.

Very truly yours,

*Charles E. Platt*

Charles E. Platt  
Superintendent

8304140463 750205  
PDR ADDCK 05000244  
S PDR

CEP:fah

cc: Mr. J. F. O'Leary, AEC  
Mr. G. J. Swarthout, RG&E