

# OPERATING DATA REPORT

DOCKET NO. 50-339  
 DATE 03-04-84  
 COMPLETED BY Joan N. Lee  
 TELEPHONE (703) 894-5151 X2527

## OPERATING STATUS

Notes: This page re-submitted  
 do to error in calculation  
 in cumulative figures.

1. Unit Name: North Anna 2
2. Reporting Period: February 1984
3. Licensed Thermal Power (MWt): 2775
4. Nameplate Rating (Gross MWe): 947
5. Design Electrical Rating (Net MWe): 907
6. Maximum Dependable Capacity (Gross MWe): 939
7. Maximum Dependable Capacity (Net MWe): 890
8. If Changes Occur in Capacity Ratings (Items No. 3 thru 7) Since Last Report, Give Reasons:

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	696	1,440	28,152
12. Number of Hours Reactor Was Critical	621.7	1,365.7	21,012.6
13. Reactor Reserve Shutdown Hours	3.5	3.5	3,783.5
14. Hours Generator On-Line	584.5	1,328.5	20,835.6
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	1,474,396	3,431,253	53,847,294
17. Gross Electrical Energy Generated (MWH)	483,285	1,123,980	17,838,347
18. Net Electrical Energy Generated (MWH)	457,966	1,065,901	16,917,983
19. Unit Service Factor	84.0	92.3	74.0
20. Unit Availability Factor	84.0	92.3	74.0
21. Unit Capacity Factor (Using MDC Net)	73.9	83.2	67.6
22. Unit Capacity Factor (Using DER Net)	72.5	81.6	66.3
23. Unit Forced Outage Rate	6.2	6.2	* 14.5
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

Scheduled Maintenance 03-30-84

Unit 2 Refueling Outage 09-21-84

25. If Shut Down At End Of Report Period, Estimated Date of Startup:
26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY  
 INITIAL ELECTRICITY  
 COMMERCIAL OPERATION

8405020209 840416  
 PDR ADOCK 05000338  
 R PDR