

TELECOPY

Ginna Station
June 13, 1973

Mr. James P. O'Reilly, Director
U.S.A.E.C.
Directorate of Regulatory Operations
Region I
970 Broad St.
Newark, N.J. 07102

RE: Abnormal Occurrence 73-4, Ginna Station.
Failure of 1C Safety Injection Pump (SIP) to start manually from Bus 16
when control switch was closed at the Control Board on June 12, 1973.

Dear Mr. O'Reilly:

This is a repeat of the abnormal occurrence (73-3) that was reported to you on
June 11, 1973.

After further maintenance work was performed on the 1C SIP Breaker from Bus 16
on June 12, 1973, the Breaker failed to operate properly when it was being re-
turned to service. The 1C SIP remained operable from Bus 14 throughout the
maintenance on Bus 16 breaker.

Further investigation indicated that the problem was in the cell switch for the
Bus 16 breaker. The cell switch was adjusted and the 1C SIP was started satis-
factorily 3 times.

The PORC met and they consider the problem resolved, however, they recommend
that further investigation be made with Westinghouse on the proper application
of this type cell switch.

Very truly yours,


Charles E. Platt
Charles E. Platt
Superintendent

CEP:jmb

Distribution:

Mr. J. F. O'Leary, AEC Washington

G. J. Swarthout, RG&E	L. S. Lang, RG&E
F.E. Drake, RG&E	J. E. Arthur, RG&E
K.W. Amish, RG&E	R. R. Koprowski, RG&E
L.D. White, Jr., RG&E	

MEMO ROUTE SLIP		See me about this. Note and return	For concurrence. For signature	For action. For information
Form AEC-94 (Rev. May 11, 1961) AEC M 0250				
TO (Name and unit)	INITIALS	REMARKS		
H. D. Thornburg, Chief, FS&EB	DATE	Licensee: Rochester Gas & Electric Corp.		
		Docket No.: 50-244		
		Abnormal Occurrence: 73-4		
TO (Name and unit)	INITIALS	REMARKS		
RO:HQ (5) DR Central Files (1) Regulatory Standards Dir. of Licensing (13)	DATE	The attached report from the subject licensee is		
		forwarded in accordance with RO Manual Chapter 1000		
TO (Name and unit)	INITIALS	REMARKS		
RO Files	DATE	The action taken by the licensee is considered		
		appropriate. Followup will be performed during		
		the next inspection as appropriate. Copies of		
FROM (Name and unit)	REMARKS			
 R. T. Carlson, RO:I		the report have been forwarded to the PDR, Local		
		PDR, NSIC, DTIE and State representatives. The		
		licensee will submit a 10 day written report to		
PHONE NO.	DATE	Licensing.		
	6/14/73			

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445

U.S. ATOMIC ENERGY COM.
DIVISION OF COMPLIANCE

1973 JUN 18 PM 9 07

RECEIVED