

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-336

UNIT NAME Millstone 2

DATE

COMPLETED BY R. BorchertTELEPHONE (203) 447-1791

Ext. 4418

REPORT MONTH January 1984 (revised)

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
5	830528	S	252.5	C	4	N/A	N/A	N/A	Completion of Refuel and Maintenance Outage from previous month.
1	840111	F	55.1	H	3	84-02	JB	TC	Reactor Trip on Steam General Low-Level, while at 15% Rx Power. Resumed Normal Start-up procedures. See LER 84-02.