

James G. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U.S. Atomic Energy Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Telecopied: Date 23 Jan 75

CE 1530

DC 1550

50-237

BY ONE

cc:

J. F. O'Leary, Director
Directorate of Licensing
U.S. Atomic Energy Commission
Washington, D.C. 20545



SUBJECT: DPR- A, Dresden Nuclear Power Station, Unit 2

This will confirm a conversation with Mr. Johnson

your office at 1445 hrs this date concerning Low Pressure

- ① COOLANT INJECTION VALVE 2-1501-25B, THE "B" LOOD CHECK VALVE TO PASS A LOCAL LEAK RATE TEST DURING CURRENT REVEALING OUTAGE, LEAKAGE WAS APPROXIMATELY TWICE THE ALLOWED LEAKAGE
- ② SET POINT OF LIS-263-73B OUT OF LIMITS DUE TO LOOSE MERCURY SWITCH MOUNTING BRACKET SCREENS. SET POINT WAS 258"AP AND LIMIT IS 257"AP. WHEN SCREENS WERE TIGHTENED, SET POINT RETURNED TO ORIGINAL 254"AP VALUE.
- ③ CORE SPRAY SYSTEM STOP CHECK VALVE 1402-8B AGAIN STUCK OPEN DEPRESSURIZING THE CORE SPRAY HEADER AT 1315 TODAY. VALVE HAD BEEN INSPECTED AND SATISFACTORILY TESTED AFTER PREVIOUS FAILURE.

50-237
inad

8304150061 750123
PDR ADCK 05000237
S PDR

COPY SENT REGION III

To Call:

CE - 5-858-2650x16 (auto)

DC - 9-1-301-973-7617 (auto) - on 6

Station Dist: Originator (copy)

Incident File (copy)

Telegram File (original)

B. B. Stephenson, Superintendent

Dresden Nuclear Power Station

Commonwealth Edison Company

R.R. #1

Morris, IL 60450

Telephone: 815-942-2920/2921x212

(teletype x262)