

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

TELECOPY

TELEPHONE  
AREA CODE 716 546 2700

Ginna Station  
June 11, 1973

Mr. James P. O'Reilly, Director  
970 Broad Street  
Newark, New Jersey 07102

Re: Abnormal Occurrence 73-3, Ginna Station - Failure of 1C Safety  
Injection Pump to start manually from Control Board on 6/11/73

Dear Mr. O'Reilly:

This morning at 0409, while the operators were performing a periodic test (PT-2.1), the C Safety Injection Pump failed to start manually from Bus 16 when the operator closed the control switch at the control board.

The A & B Safety Injection Pumps had been previously tested satisfactorily per PT-2.1 at 0350 and 0407. When the pump failed to start and the white disagreement light illuminated on the breaker control switch, the operator immediately cleared the disagreement light and attempted a second start of the C Safety Injection Pump. This time it started satisfactorily and PT-2.1 was successfully completed on the C Safety Injection Pump.

After the test was completed, the Shift Foreman had the operator start the C Safety Injection Pump from Bus 14. It started satisfactorily. The C S. I. Pump was then started successfully once again from Bus 16.

The electricians performed further investigation by using maintenance procedure M-32, procedure for use of multi-amp test unit to check the overcurrent trip devices. All devices were tested and found to function satisfactorily.

The Plant Operations Review Committee met and recommended further tests be made of the control switch and breaker for the C Safety Injection pump feed

*Charles E. Platt*  
Charles E. Platt  
Superintendent

CEP:fah  
Distribution List Attached

8304150062 730611  
PDR ADDCK 05000244  
S PDR

*Ten Day  
Writer  
Permit  
Submitted  
See 4-11-73  
Reported  
6-21-73*

*Handy  
5-2-74*

6/11/73

Distribution:

J. P. O'Leary, AEC Washington  
G. J. Swarthout, RG&E  
F. E. Drake       "  
K. W. Amish       "  
L. D. White, Jr.   "  
L. S. Long       "  
J. E. Arthur       "  
R. R. Koprowski   "

RECEIVED  
JUN 14 1973

RECEIVED  
JUN 14 1973

RECEIVED

MEMO ROUTE SLIP		See me about this.	For occurrence.	For action.
Form AIC-93 (Rev. May 11, 1967) FILE M 0240		Note and return	Signature	For information
TO (Name and unit)	INITIALS	REMARKS		
H. D. Thornburg, Chief, FS&EB		Licensee: Rochester Gas & Electric Corp.		
	DATE	Docket No.: 50-244		
		Abnormal Occurrence: Report dated 6/11/73		
TO (Name and unit)	INITIALS	REMARKS		
RO:HQ (5) DR Central Files (1) Regulatory Standards (3) Dir. of Licensing (13)	DATE	The attached report from the subject licensee is		
		forwarded in accordance with RO Manual Chapter 1000		
TO (Name and unit)	INITIALS	REMARKS		
RO Files		The action taken by the licensee is considered		
	DATE	appropriate. Followup will be performed during		
		the next inspection as appropriate. Copies of		
FROM (Name and unit)	REMARKS			
R. T. Carlson, RO:I		the report have been forwarded to the PDR, Local		
		PDR, NSIC, DTIE and State representatives. The		
		licensee will submit a 10 day written report to		
PHONE NO.	DATE	Licensing.		
	6/11/73			

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445