



Telegram

446P EDT AUG 19 70 PB394 SYF264

SY RHA249 BR PDF 4 EXTRA ROCHESTER NY 19 258P EDT

R W KIRKMAN, DIRECTOR REGION 1 DIVN OF COMPLIANCE USAEC

970 BROAD ST NEWARK NJER

THIS IS TO CONFIRM MY CONVERSATION AT 1420 HOURS THIS DATE.
WITH MR MOSLEY IN REGARDS TO AN ABNORMAL OCCURANCE THAT CAUSED
A CONDITION THAT WAS DETECTED ON AUGUST 18 1970 AT ABOUT 1500
HOURS THE PERIODIC TESTING OF REACTOR PROTECTION SYSTEM CHANNEL
3 BEGAN, WITH THE OVER POWER DELTA-T TRIP PROTECTION FOR THIS
CHANNEL PLACED IN THE TRIP MODE STOP AT 1533 HOURS THE OVERPOWER
ROD STOP AND REACTOR TRIP BISTABLE, TC-407/B WAS FOUND TO BE
FAULTY STOP IMMEDIATE REPLACEMENT OF THIS BISTABLE WAS BEGUN
STOP

ON AUGUST 19 1970 IT WAS DECIDED, SINCE THE FAULTY BISTABLE
WOULD AFFECT THE REACTOR TRIP SET POINT, TO INVESTIGATE THE
EXTENT OF THIS AFFECT STOP THE RESULTS OF THIS INVESTIGATION

8304150091 700826
PDR ADDCK 05000244
PDR
S

(RS-69)

B10R/Staff
8/25/70
LX

03009



Telegram

SHOWED THAT THE CONDITION OF THE FAULTY BISTABLE HAD BEEN SUCH
AS TO CAUSE THE SET POINT, FOR STABLED CONDITIONS, TO BEGIN
EXCESS OF THE PRESCRIBED FORMULA IN TECHNICAL SPECIFICATIONS,
SECTION 2.3.1.2.E OF LIMITING SAFETY SYSTEM SETTING STOP

JAMES F SWEET OPERATIONS ENGINEER GINNE STATION ROCH GAS
AND ELEC

1420 18 1970 18 1970 1500 3 DELTA-T 1533 TC-407/B 19 1970
2.3.1.2.E GINNE
(319).

MEMO ROUTE SLIP

Form AEC-93 (Rev. May 14, 1947) AECM 0240

See me about this.
Note and return.

For conc. se.
For signature.

For action.
For information.

TO (Name and unit) J. P. O'Reilly Chief, RI&EB, CO:HQ	INITIALS DATE	REMARKS Forwarded herewith is a telegram from Rochester Gas And Electric Corporation received at CO:I 8/20/70.
TO (Name and unit)	INITIALS DATE	REMARKS
TO (Name and unit)	INITIALS DATE	REMARKS
FROM (Name and unit) E. M. Howard Sr. Reactor Inspector CO:I	REMARKS <div style="text-align: right;">03000</div>	
PHONE NO. 3941	DATE 8/21/70	

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1968 O-294-519