



# Telegram

737P EST APR 23 71 PB573 SYD433  
SY RHA335 DF NL PDF ROCHESTER NY 23  
R W KIRKMAN, DIRECTOR REGION 1 DIVN COMPLIANCE USAEC  
970 BROAD ST NEWARK NJER

THIS IS TO CONFIRM MY CONVERSATION AT 1632 THIS DATE WITH FLOYD CANTRELL IN REGARDS TO AN ABNORMAL OCCURANCE AT GINNA STATION THURSDAY NIGHT APRIL 22ND 1971 RGE MEN WERE DOING THE DIESEL GENERATOR LOAD AND SAFE GUARD SEQUENCE TEST THE UNIT WAS IN THE COLD SHUTDOWN CONDITION WHEN THEY ACTUATED THE MANUEL, SAFETY INJECTION BUTTON THE, COST OF THE EXISTING ELECTRICAL HOOKUP WE LOST THE 1B INSTRUMENT BUS THE FEED FOR THE A CONCENTRATED BORIC ACID STORAGE TANK LEVEL INSTRUMENTATION WAS CONNECTED TO THIS BUS SO THE INSTRUMENTATION SHOWED LOW LEVEL IN THIS TANK AND THIS INDICATION WILL PREVENT VALVES 826A 826B 826C 826D TO OPEN THIS WAS REVIEWED BY THE PORC COMMITTEE ON APRIL 23RD 1971 AND THE ELECTRICAL SPEED FOR THE A CONCENTRATED BORIC

SF-1201 (R5-69)



# Telegram

ACID STORAGE TANK LEVEL INSTRUMENTATION WILL BE MOVED TO AN INSTRUMENT BUS SUPPLIES BY AN UNVERTER

CHARLES E PLATT SUPERINTENDENT GINNA STATION ROCHESTER GAS AND ELECTRIC CORP

1632 22 1971 RGE 826A 826B 826C 826D 23 1971.

*13/5/71 4/30/71*

*MA*

*JLX*  
*LK*

8304150239 710522  
PDR ADOCK 05000244  
S PDR

SF-1201 (R5-69)