



Telegram

1159A EST MAY 18 70 PD215

SYC093 SY RHB067 ML NL POF TORH ONTARIO NY 15 310P EDT

R W KIRKMAN DIR REGION 1 DIVN OF COMPLIANCE (SUSPECTED DUPLICATE RUSH DLY) (NFL) 970 BROAD ST. 1122

USAEC 90 BROAD ST NEWARK N.J.R

THIS IS TO CONFIRM MY CONVERSATION OF 0930 THIS DATE WITH FLOYD CANTRELL IN REGARDS TO ABNORMAL ACCURANCE THAT HAPPENED AT 2345 ON 5-14-70 AT THE GINNA STATION. AT 2200 ON 5-14-70 WE CONDUCTED A 100 PERCENT LOAD REJECTION TEST. AT 2345, WHILE SHOP AT SHUTDOWN CONDITION. THE REACTOR OPERATOR CLOSED THE MAIN STEAM LINE INSULATION VALVES MSIV-1A AND MSIV-1B FROM THE CONTROL ROOM. THE PANNEL BOARD INDICATING LIGHT SHOWED THAT THE MSIV-1B DID NOT CLOSE. IMMEDIATE INVESTIGATION FOUND THAT ALL SOLENOID VALVES HAD OPERATED. THE MSIV-1B VALVE WAS THEN OPERATED LOCALLY SEVERAL TIMES AND IT WAS OBSERVED THAT THE VALVE DID NOT CLOSE COMPLETELY EVERY TIME. THE PACKING

SF-1201 (RS-66)



Telegram

GLAND WAS ADJUSTED AND THEN WE WERE ABLE TO COMPLETELY CLOSE THE VALVE. DURING THE SCHEDULE TWO WEEK OUTAGE OF THE UNIT WE WILL CHECK THE OPERATION OF THE VALVE AND THE OPERATING CYLINDER. THE VALVE WILL BE RETESTED AFTER THE REACTOR IS RETURN TO OPERATING TEMPERATURE AND PRESSURE

CHARLES E PRATT SUPERINTENDENT GINNA STATION ROCHESTER GAS AND ELECTRIC

0930 2345 5-14-70 2200 5-14-70 100 2345 MSIV-1A MSIV-1B MSIV-1B DID MSIV-1B.

QQQ ULM

8304150331 700522
PDR ADDCK 05000244
S PDR

SF-1201 (RS-66)

MEMO ROUTE SLIP

Form AEC-93 (Rev. May 14, 1947) AECM 0240

See me about this.

For concu

For action.

Note and return.

For signature.

For information.

TO (Name and unit)

INITIALS

REMARKS

J. P. O'Reilly
CO:HQ

DATE

Re: ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

The attached TWX dated 5/18/70 is forwarded as per

TO (Name and unit)

INITIALS

REMARKS

Provisional Instruction No. 1000/1.

DATE

Attachment:
Orig & 1 cy TWX

TO (Name and unit)

INITIALS

REMARKS

DATE

FROM (Name and unit)

REMARKS

Paul
R. T. Carlson
CO:I

Copy sent to PDR & NSIC.

01665

PHONE NO.

DATE

X-3944

5/18/70

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1965 O-294-619