



Telegram

1216P EST MAR 6 70 PB111 SYF121  
SY RHC053 GS PDF 3 EXTRA ROCHESTER NY 6 1132A EST  
R W KIRKMAN, DIRECTOR REGION NBR 1 DIV OF COMPLIANCE

USAEC 90 BROAD ST NEWARK NJER

THIS IS TO CONFIRM MY CONVERSATION OF 1000 THIS DATE WITH DOYLE  
HUNNICUTT IN REGARDS TO AN ABNORMAL OCCURENCE THAT WAS DISCOVERED  
THIS MORNING WHEN WE DID OUR SURVEILLANCE TEST OF THE PERSONNEL  
AIRLOCK IN THE EQUIPMENT HATCH. AT 0800 THIS MORNING THE TEST  
INDICATED EXCESSIVE AIR LEAKAGE ALONG THE SHAFT THAT PENETRATES  
TO THE OUTSIDE AND INSIDE HAND CONTROL WHEELS. REPAIRS WERE  
STARTED IMMEDIATELY AND WILL CONTINUE AROUND THE CLOCK UNTIL  
COMPLETED. PORC COMMITTEE WILL MEET THIS AFTERNOON TO DISCUSS  
THE PROBLEM

CHARLES E PLATT SUPERINTENDENT CINNA STATION ROCHESTER GAS  
AND ELECTRIC CORP

SF-1201 (RS-69)

*IS/TN has seen*

1000 0800 PORC  
(1141).

B304150353 700313  
PDR ADOCK 05000244  
S PDR

SF-1201 (RS-69)

# MEMO ROUTE SLIP

Form AEC-95 (Rev. May 14, 1947) AECM 0240

See me about this.

For concur

For action.

Note and return.

For signature.

For information.

TO (Name and unit)

INITIALS

REMARKS

J. P. O'Reilly, Chief  
Reactor Inspection and  
Enforcement Branch,  
CO:HQ

DATE

ROCHESTER GAS AND ELECTRIC COMPANY

The attached telegraphic report from RG&E is for-  
warded in accordance with PI 1000/3. The incident  
was also discussed in Inquiry Memorandum 244/70-C.

TO (Name and unit)

INITIALS

REMARKS

DATE

TO (Name and unit)

INITIALS

REMARKS

DATE

FROM (Name and unit)

REMARKS

N.C. Moseley, Sr.  
Reactor Inspector,  
CO:I

PHONE NO. 3942

DATE 2/6/70

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1968 O-294-619