

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) D. C. COOK PLANT UNIT - 2										DOCKET NUMBER (2) 0 5 0 0 0 3 1 6					PAGE (3) 1 OF 0 1	
TITLE (4) CONTAINMENT TYPE B AND C LEAK TESTS																
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)						
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)			
0 3	3 1	8 4	8 4	0 0 5	0 0	0 4	3 0	8 4					0 5 0 0 0			
OPERATING MODE (9) 5			THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11):													
POWER LEVEL (10) 0 0 0		20.402(b)				20.406(c)				50.73(a)(2)(iv)				73.71(b)		
		20.406(a)(1)(i)				50.38(c)(1)				50.73(a)(2)(v)				73.71(c)		
		20.406(a)(1)(ii)				50.38(c)(2)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 366A)		
		20.406(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(viii)(A)						
		20.406(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)						
		20.406(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(a)						
LICENSEE CONTACT FOR THIS LER (12)																
NAME A. A. BLIND TECHNICAL-ENGINEERING SUPERINTENDENT										TELEPHONE NUMBER 6 1 6 4 6 5-5 9 0 1						
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																
CAUSE	SYSTEM	COMPONENT	MANUF. TURER	REPORTABLE TO NPD'S	CAUSE	SYSTEM	COMPONENT	MANUF. TURER	REPORTABLE TO NPD'S							
B	B'D	I S V	X	9 9 9 Y												
SUPPLEMENTAL REPORT EXPECTED (14)										EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR		
X YES (If yes, complete EXPECTED SUBMISSION DATE)										NO		0 7		0 1	8 4	

WHILE SHUTDOWN FOR A REFUELING OUTAGE, THE ACCUMULATED LEAKAGE FOUND WHILE PERFORMING THE TYPE B AND C LEAK RATE TESTS ON CONTAINMENT PENETRATIONS EXCEEDED THE L.C.O. VALUE (0.60 La) OF TECHNICAL SPECIFICATION 3.6.1.2.b. ON 3-31-84, THE ACCUMULATED LEAKAGE WAS FOUND TO BE 0.64 La.

THOSE CONTAINMENT ISOLATION VALVES THAT EXHIBIT EXCESSIVE LEAK RATES ARE BEING REPAIRED AND RETESTED TO INSURE THE COMBINED LEAK RATES ARE WITHIN ALLOWABLE LIMITS. THE B AND C LEAK RATE TESTING IS STILL IN PROGRESS AND WILL NOT BE COMPLETED UNTIL THE END OF THE REFUELING OUTAGE.

THIS IS AN INTERIM REPORT. THE FINAL REPORT WILL BE SUBMITTED FOLLOWING COMPLETION OF THE B AND C LEAK RATE TESTS.

8405030092 840430
PDR ADOCK 05000316
S PDR

IE 22



INDIANA & MICHIGAN ELECTRIC COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

April 30, 1984

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Operating License DPR-74
Docket No. 50-316

Document Control Manager:

In accordance with the criteria established by 10CFR50.73
entitled Licensee Event Reporting System, the following
report/s are being submitted:

RO 84-005-0

Sincerely,

W.G. Smith, Jr.
W.G. Smith, Jr.
Plant Manager

/cbm

Attachment

cc: John E. Dolan
J.G. Keppler, RO:III
M.P. Alexich
R.F. Kroeger
H. Brugger
E.R. Swanson, RO:III
R.C. Callen, MPSC
G. Charnoff, Esq.
J.M. Hennigan
R.O. Bruggee, EPRI
INPO
PNSRC
J.F. Stietzel
E.L. Townley
Dir., IE
Dir., MIPC

IE22
11