



Telegram

418P EST FEB 3 72 PA205 MA141

M RHA099 ML PDF 1 EXTRA ROCHESTER NY 3 1119A EST

JAMES P O'REILLY DIRECTOR REGION 1 DIVISION OF COMPLIANCE

USAEC 970 BROAD ST NEWARK NJER

THIS IS TO CONFIRM MY CONVERSATION AT 0920 HOURS THIS DATE
WITH WALTER BAUNACK OF YOUR OFFICE IN REGARDS TO AN ABNORMAL
OCCURENCE AT GINNA STATION.

AT 0135 HOURS ON FEBRUARY 3 1972 THE OPERATORS WERE CONDUCTING
THE BI-WEEKLY PT6.3 SURVEILLANCE TEST THE POWER RANGE HIGH
FLUX TRIP SET POINTS ON NUCLEAR POWER N-41 WAS FOUND TO BE
AT 110 PERCENT.

THE CHANNEL WAS CHECKED AND THE NEGATIVE POWER SUPPLY VOLTAGE
HAD DRIFTED OUT OF ITS SPECIFICATION. IT WAS REALIGNED TO WITHIN
SPECIFICATION AND RETESTED USING PROCEDURE PT6.3 IT WAS FOUND
TO BE OPERATING NORMALLY

CHARLES E PLATT SUPERINTENDENT GINNA STATION ROCHESTER GAS

2 0178

Copy sent PDR

8304200029 720207
PDR ADDCK 05000244
PDR

1 (RS-89)



Telegram

— PARAS/3

AND ELECTRIC

0920 0135 3 1972 PT6.3 N-41 110 PT6.3
(1150).