

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

April 25, 1984

Mr. J. G. Keppler, Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr. Keppler:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
I.E. Bulletin 84-02: Failures of General Electric Type HFA Relays
In Use in Class 1E Safety Systems

In response to the "Actions for All Holders of Operating Licenses or Construction Permits" in the referenced I.E. Bulletin:

A review of relays used in Class 1E safety systems has verified that there are no General Electric type HFA relays used in Class 1E safety systems at the Kewaunee Nuclear Power Plant.

Approximately twelve (12) hours of staff time was expended to prepare and review this response.

Very truly yours,

A handwritten signature in cursive script, appearing to read "Carl Giesler".

Carl Giesler
Vice President - Nuclear Power

JLB/js

cc - Mr. S. A. Varga, US NRC
Mr. Robert Nelson, US NRC
Director, Office of I&E, US NRC

8405040042 840425
PDR ADOCK 05000305
Q PDR

APR 27 1984

IE11

1/0