

**Western union**

**Telegram**

VEE274(1453)(1-018775C326)PD 11/21/72 1450

1972 NOV 21 PM 1 57

ICS IPMVEIC MVN

ZCZC 00141 TDVE MORRIS ILL 73 11-21 1145A CST

PMS MR BOYCE GRIER WUX DIRECTOR DIVISON OF COMPLIANCE

REGENT 3 US ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD

GLEN ELLYN ILL 60137

SUBJECT; DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2;

THIS WILL CONFIRM THE CONVERSATION WITH MRDANCE OF YOUR OFFICE

AT 1030 HOURS THIS DATE CONCERNING DEVIATION REPORTS D-2-72-3 IN WH

ICH ALL MAIN STEAM LINE LOW PRESSURE SWITCHES WERE FOUND TO BE BEL

OW THE TECHNICAL SPECIFICATION LIMITS OF 850 PSIG. ALL

SWITCHES PS-2-261-30 A THROUGH B WERE RESET TO 871 PLUS OR MINUS

4 PPSIG

TELEGRAMS (OTHER THAN MONEY ORDERS) 28 3-2

WP WORDEN

Is PHYSICAL DELIVERY req. selected? (YES-AGENT, NO-ADDRESSER)

SUPERINTENDENT

AGENT SECTION

ADDRESSER SECTION

COMMONWEALTH EDISON

Nbr. & Name

Nr. 312-858-2660

Date dtd

11-21

Time dtd

5:02P

To mag

By PG

Sp. by called or filed

mail

Attempts to deliver (Indicate DA or BY)

8F-1201 (R5-89)

DRESDEN NUCLEAR STATION

RR NO 1

MORRIS ILL

8304210175 721121  
PDR ADOCK 05000237  
S PDR

7-(R5-89)

50-239

Eng.

0