



Telegram

1235P EST OCT 26 72 DEB365

SSH065 DJ: ENA043 DEA441 DEG057 (0748 1-0033930300) PD 10/26/72
0746 ICS IPMVEITA MVN 7070 00012 TDVE MORRIS ILL 85 10-25 445P
CDT

FMS MRS BOYCE GRIER DIRECTOR DIVN OF COMPLIANCE REGION 3
U S ATOMIC ENERGY COMMISSION TWX 799 ROOSEVELT ROAD GLEN ELLYN
ILL (MIS ROUTED) 40137

SUBJECT DPR -1 DRESDEN NUCLEAR POWER STATION UNIT 2 THIS
WILL CONFIRM A CONVERSATION WITH MR DANCE OF YOUR OFFICE AT
1625 HOURS THIS DATE CONCERNING THE DRAFTING OF MAIN STEAM
LINE LOW PRESSURE SWITCHES NUMBERS 2-261-30A AND 2-261-30 C
SWITCHES ARE REQUIRED TO OPERATE
T 850 PSI AT THE STEAM LINE BUT AS FOUND 2-261-30 A TRIPPED
AT 849 AND 2-261-30 C TRIPPED AT 847 REACTOR WAS IN COLD SHUT
DOWN AT THE TIME SWITCHES WERE RE- SET TO TRIP AT 855 855
PSI AT STEAM LINE

9P-1201 (R5-69)

430A

W P WORDEN SUPERINTENDENT DRESDEN NUCLEAR POWER STATION .

50-237
inquiry

312 855-2660
TELEGRAMS (OTHER THAN ORDERS)

INSTRUCTIONS TO THE TELEGRAM

10-124-337A MG by WPB
delivered (signature)

8304210193 721121
PDR ADOCK 05000237
PDR

SF-5