



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.  
VICE PRESIDENT

TELEPHONE  
AREA CODE 716 546-2700

November 24, 1975

Director of Nuclear Reactor Regulation  
ATTN: Mr. Karl Goller  
Assistant Director for Operating Reactors  
Division of Reactor Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555



Subject: Inspection of Hydraulic Shock Absorbers (Snubbers)  
R. E. Ginna Nuclear Power Plant, Unit No. 1  
Docket No. 50-244

Dear Mr. Goller:

In accordance with Mr. Skovholt's letter of October 1, 1973, concerning periodic inspection of hydraulic shock absorbers (snubbers), an inspection of all snubbers outside of containment was completed on November 13, 1975.

All snubbers were considered operable at this inspection. No fluid additions were necessary. One of the Bergen-Paterson units was observed to have developed wear at its attachment pin. This does not affect its seismic performance. The unit will be repaired when conditions permit.

Very truly yours,

*L. D. White, Jr.*  
L. D. White, Jr.

8304210239 751223  
PDR ADOCK 05000244  
G PDR

13456

COPY SENT REGION