



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.  
VICE PRESIDENT

TELEPHONE  
AREA CODE 716 546-2700

August 11, 1975

Mr. Karl Goller  
Assistant Director for Operating Reactors  
Division of Reactor Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Subject: Inspection of Hydraulic Shock Absorbers (Snubbers)  
R. E. Ginna Nuclear Power Plant, Unit No. 1  
Docket No. 50-244

Dear Mr. Goller:

In accordance with Mr. Skovholt's letter of October 1, 1973 concerning periodic inspection of hydraulic shock absorbers (snubbers), an inspection of all snubbers, both inside and outside of containment, was completed on July 31, 1975.

All snubbers were considered operable at this inspection. Fluid addition was made to one Bergen-Paterson unit outside containment although there was no leakage exhibited.

A subsequent inspection of snubbers outside of containment was made on August 5, 1975. All units were considered operable and no fluid additions were necessary.

Very truly yours,

*L. D. White, Jr.*  
L. D. White, Jr.

50-244  
Inquiry  
2012

8304210251 751223  
PDR ADOCK 05000244  
G PDR