

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

TELEPHONE: 467-4000
TELETYPE: 467-4000
FAX: 467-4000

TELEPHONE: 546-2700
AREA CODE: 716 546-2700

July 1, 1974



Mr. Karl Goller
Assistant Director for Operating Reactors
Directorate of Licensing
U. S. Atomic Energy Commission
Washington, D.C. 20545

Subject: Inspection of Hydraulic Shock Absorbers (Snubbers)
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. Goller:

In accordance with Mr. Skovholt's letter of October 1, 1973, concerning periodic inspection of hydraulic shock absorbers (snubbers), an inspection of all snubbers, both inside and outside of containment, was conducted on June 19 and 20, 1974 by station maintenance personnel.

A small quantity of fluid was added to two of the Bergen-Paterson snubber accumulators outside the containment. All snubbers were considered operable at this inspection.

During an outage on June 21, 1974 through June 26, 1974 these two units as well as a third unit were replaced or repaired. Plans for this action were stated in our letter to you dated June 10, 1974.

Very truly yours,

Keith W. Amish

Amish
50-244
Rob
73-3

8304210321 751223
PDR ADOCK 05000244
Q PDR

COPY SENT REGION I