



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

GRANGER E. GREEN  
VICE PRESIDENT

TELEPHONE  
AREA CODE 716 546-2700

June 10, 1974

Mr. Karl Goller  
Assistant Director for Operating Reactors  
Directorate of Licensing  
U. S. Atomic Energy Commission  
Washington, D.C. 20545

Subject: Inspection of Hydraulic Shock Absorbers  
(Snubbers)  
R. E. Ginna Nuclear Power Plant, Unit No. 1  
Docket No. 50-244



Dear Mr. Goller:

In accordance with Mr. Skovholt's letter of October 1, 1973, concerning periodic inspection of hydraulic shock absorbers (snubbers), an inspection of all snubbers, both inside and outside of containment, was conducted on May 23, 1974 by station maintenance personnel.

Fluid was added to six of the Bergen-Paterson snubbers outside the containment. Three of these exhibited minor leakage of fluid, and will be repaired or replaced at the first hot shutdown of at least 48 hours. All snubbers were considered operable at this inspection.

Very truly yours,

Granger E. Green

8304210325 751223  
PDR ADOCK 05000244  
Q PDR

*Handwritten:*  
Unit  
(R&B 733)  
50-244

COPY SENT REGION 1

5367