

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

KEITH W. AMISH
SENIOR VICE PRESIDENT
ELECTRIC AND STEAM

TELEPHONE
AREA CODE 716 546-2700

December 3, 1973

Mr. Donald K. Skovholt
Assistant Director for Operating Reactors
Directorate of Licensing
U. S. Atomic Energy Commission
7920 Norfolk Avenue
Bethesda, Maryland 20014



Subject: Inspection of Hydraulic Shock Absorbers (Snubbers)
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. Skovholt:

In accordance with your letter of October 1, 1973 concerning periodic inspection of hydraulic shock absorbers (snubbers), an inspection of all Ginna Plant snubbers was conducted November 19 and 20, 1973.

All units were considered operable and the only deficiency evident was one minor problem detected on Unit No. FW-9 located on the "B" steam generator feedwater line. The grease fitting on the accumulator was leaking slightly and was replaced with a new fitting on an isolation valve. Fluid leaking from this accumulator since the last inspection was slight and sufficient fluid was available for proper snubber operation.

Very truly yours,

Keith W. Amish
K. W. Amish

xc: Mr. J. P. O'Reilly

8304210335 751223
PDR ADDCK 05000244
PDR
Q

8658

COPI SENT REGION