

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE 764

COLUMBIA, SOUTH CAROLINA 29218

O. W. DIXON, JR.  
VICE PRESIDENT  
NUCLEAR OPERATIONS

April 10, 1984

APR 17 12:45

Mr. J. P. O'Reilly,  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II, Suite 2900  
101 Marietta Street, N.W.  
Atlanta, GA 30303

Subject: Virgil C. Summer Nuclear Station  
Docket No. 50/395  
Operating License No. NPF-12  
NRC IE Bulletin No. 83-08

Dear Mr. O'Reilly:


On December 28, 1983, the NRC issued IE Bulletin No. 83-08, "Electrical Circuit Breakers with an Undervoltage (UV) Trip Feature in Use in Safety-Related Applications Other Than the Reactor Trip System." Licensees were requested to identify applications of Westinghouse type DB, Westinghouse type DS and General Electric type AK-2 circuit breakers with the UV trip feature as well as other types of breakers by other manufacturers that use a UV trip feature in safety-related applications.

In a response dated March 19, 1984, South Carolina Electric and Gas Company (SCE&G) reported that it had not identified any application of Westinghouse type DB, Westinghouse type DS or General Electric type AK-2 circuit breakers with the undervoltage trip feature in safety-related systems, other than the Reactor Trip Breakers, at the Virgil C. Summer Nuclear Station.

In response to a recent NRC question, SCE&G has reviewed all other circuit breakers and has identified no other circuit breakers that utilize the undervoltage trip feature in safety-related applications.

I declare the statements and matters set forth herein are true and correct to the best of my knowledge, information and belief.

Very truly yours,



O. W. Dixon, Jr.

HID/OWD/gj  
cc: (see page #2)

8405070026 840410  
PDR ADCK 05000395  
Q PDR

1/0  
IE11

Mr. J. P. O'Reilly,  
NRC IE Bulletin No. 83-08  
April 10, 1984  
Page #2

cc: V. C. Summer  
T. C. Nichols, Jr./O. W. Dixon, Jr.  
E. H. Crews, Jr.  
E. C. Roberts  
W. A. Williams, Jr.  
D. A. Nauman  
Group Managers  
O. S. Bradham  
C. A. Price  
D. A. Lavigne  
C. L. Ligon (NSRC)  
K. E. Nodland  
R. A. Stough  
G. Percival  
C. W. Hehl  
J. B. Knotts, Jr.  
I&E Washington  
NPCF  
File