



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.  
VICE PRESIDENT

TELEPHONE  
AREA CODE 716 546 2700

September 9, 1975

Mr. Karl Goller  
Assistant Director for Operating Reactors  
Division of Reactor Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Subject: Inspection of Hydraulic Shock Absorbers (Snubbers)  
R. E. Ginna Nuclear Power Plant, Unit No. 1  
Docket No. 50-244

Dear Mr. Goller:

In accordance with Mr. Skovholt's letter of October 1, 1973, concerning periodic inspection of hydraulic shock absorbers (snubbers), an inspection of all snubbers outside of containment was completed on September 4, 1975.

All snubbers were considered operable at this inspection. No fluid additions were necessary.

Very truly yours,

L. D. White, Jr.

8304210462 751021  
PDR ADOCK 05000244  
Q PDR

9723

COPY SENT REGION I

