

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

APR 17 12:45
April 9, 1984

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Re: McGuire Nuclear Station
Docket Nos. 50-369 50-370 /

Dear Mr. O'Reilly:

This letter is a Special Report submitted as required by McGuire Nuclear Station Technical Specification 3.7.8.

Duke Power Company has a design change planned which modifies the total number of mechanical snubbers identified in the Technical Specifications. A description of the planned change follows.


Modification No. MG-10880 (Unit 1)

This modification deletes one mechanical snubber in a portion of the Safety Injection (NI) System. This snubber is being deleted as part of the Boron Injection Tank (BIT) removal. A License Amendment request was submitted on December 12, 1983 to delete the Technical Specifications associated with the BIT. A revised stress analysis has been performed without the deleted snubber which showed that stresses are within acceptable values.

A revision to Technical Specification 3.7.8 to reflect the above modification will be submitted with the next license amendment request.

Please advise if there are any questions regarding this matter.

Very truly yours,



Hal B. Tucker

GAC:glb

cc: Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4

Mr. W. T. Orders
NRC Resident Inspector
McGuire Nuclear Station

8405070123 840409
PDR ADOCK 05000369
S PDR

110
IE22