



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 11, 1984

17 P12:45

NUCLEAR PRODUCTION DEPARTMENT

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 84-018/0 - Fire
Doors Taken Out of Service for
Maintenance
AECM-84/0223

Beginning on March 6, 1984, the following fire doors were taken out of service for maintenance:

<u>Fire Door</u>	<u>Removed From Service</u>	<u>Location</u>	<u>Returned to Operability</u>
1A314	03/06/84	RPV Vibration Monitor Rm 139'	03/30/84
1A320	03/06/84	Auxiliary Main Steam Tunnel Rm 139'	03/18/84
OC501	03/07/84	Rear Passage to Control Rm	03/14/84

The doors were taken out of service due to damage as a result of heavy use.

Fire watches were established in accordance with Technical Specification 3.7.7 until the doors were repaired and restored. This is submitted as a Special Report pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation (LCO) was exceeded. This is a final report.

Yours truly,

L. F. Dale
Manager of Nuclear Services

EBS/SHH:rg

cc: See next page

8405070140 840411
PDR ADOCK 05000416
PDR
B

MISSISSIPPI POWER & LIGHT COMPANY

AECM-84/0223

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555