



Carolina Power & Light Company

P. O. Box 101, New Hill, N. C. 27562  
April 11, 1984

17 P12:46

Mr. James P. O'Reilly  
United States Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Northwest (Suite 2900)  
Atlanta, Georgia 30303

NRC-211

CAROLINA POWER & LIGHT COMPANY  
SHEARON HARRIS NUCLEAR POWER PLANT  
1986 - 900,000 KW - UNIT 1  
**STANDBY DIESEL GENERATOR, ITEM 159**

Dear Mr. O'Reilly:

On February 6, 1984, Mr. N. J. Chiangi notified the NRC (Mr. A. Hardin) of a potentially reportable item per the provisions of 10CFR50.55(e) and 10CFR, Part 21. The NRC was informed that the flexible coupling drive hubs on the drive shaft in the overspeed governor and fuel transfer pump drive of the Standby Diesel Generator may have a potential problem depending upon whether the hubs are found to be loose upon inspection. The inspection procedure from Transamerica Delaval had not been received at that time.

The inspection procedure was received from Transamerica Delaval on February 24, 1984. A field change request has been issued to direct the field to perform the inspection. Based on the current construction schedule, it is now projected that we will require until September 12, 1984 to complete our inspection and submit a report on the reportability of this item.

Thank you for your consideration in this matter.

Yours very truly,

R. M. Parsons  
Project General Manager  
Shearon Harris Nuclear Power Plant

RMP/sh

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)  
Mr. R. C. DeYoung (NRC)

8405070245 840411  
PDR ADOCK 05000403  
S PDR

110  
IE27