

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

April 17, 1984

BLRD-50-438/83-22

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

BELLEFONTE NUCLEAR PLANT UNIT 1 - INCORRECT THERMAL DATA IN PROBLEM
N4-1RK-A FROM PROGRAM "EZ" - BLRD-50-438/83-22 - SECOND INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector Linda Watson on February 16, 1983 in accordance with 10 CFR 50.55(e) as NCR BLN CEB 8303. This was followed by our interim report dated March 16, 1983. Enclosed is our second interim report. We expect to submit our next report by June 26, 1984.

If you have any questions concerning this matter, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

D S Kammer

for L. M. Mills, Manager
Nuclear Licensing

Enclosure

cc: Mr. Richard C. DeYoung, Director (Enclosure)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center (Enclosure)
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8405070397 840417
PDR ADDCK 05000438
S PDR

ENCLOSURE

BELLEFONTE NUCLEAR PLANT UNIT 1
INCORRECT THERMAL DATA IN PROBLEM N4-1RK-A FROM PROGRAM "EZ"
NCR BLN CEB 8303
BLRD-50-438/83-22
10 CFR 50.55(e)
SECOND INTERIM REPORT

Description of Deficiency

Analysis problem N4-1RK has not been qualified for the thermal loading condition on essential air compressor system piping supports. In reviewing the issued analysis problem for Design Change Request (DCR) 2372, the results were found to be wrong due to the input of incorrect thermal data. This was a result of using an unverified program "EZ" and a lack of verification procedures for the "EZ" program in generating the input data.

Interim Progress

Reanalysis of problem N4-1RK-A for qualifying the thermal condition is complete. The problem on the component qualification is being studied further.