



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14604

TELEPHONE
AREA CODE 716 546-2700

Glenn Station
February 25, 1974

Mr. James P. O'Reilly, Director
U. S. Atomic Energy Commission
Directorate of Regulatory Operations
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. O'Reilly:

In accordance with 10 CFR 20.403(b) (1), notice is hereby given of the exposure of one (1) individual to a radiation dose in excess of 5 rem in one quarter. This is a film badge reading for the first quarter of 1974. He received the exposure while doing repair work in the spent fuel pit. His cumulative dosimeter readings totaled below 3 rem for the same period.

At this time I want to make a correction to the telecopied letter I sent to you on February 20, 1974. The number of radiation doses in excess of 5 rem was only three (3) individuals. The film badge processor notified us on February 22, 1974 that a keypunch error had shown one individual exceeded 5 rem, whereas the correct number was slightly over 3 rem.

Investigation of this occurrence is continuing.

Very truly yours,

Charles E. Platt
Charles E. Platt
Superintendent

CEP:fah
Attachments (2)

8304270510 750519
PDR ADDCK 05000244
H PDR

*Platt
5/2/74*