



Carolina Power & Light Company

P. O. Box 165, New Hill, North Carolina 27562
April 16, 1984

FILE: SH N-2/18
Item 167

MQAH 84-168

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest
Atlanta, Georgia 30303

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400
MINIMUM WALL FOR SAFETY RELATED PIPING

Dear Mr. O'Reilly:

This is to confirm the April 13, 1984 telephone conversation between Mr. K. V. Hate' (CP&L) and Mr. A. Hardin (NRC). Mr. Hardin was informed that the March 14, 1984 potentially reportable item, pertaining to the conflict between the pipe wall thickness specified on the Ebasco stress isometrics and that shown on the piping line list to which material is manufactured/installed, has been evaluated and considered not to be reportable per the provisions of 10CFR50.55(e) and 10CFR, Part 21.

Thank you for your consideration in this matter.

Yours very truly,

N. J. Chiangi by KBH

NJC/mt

cc: Mr. R. C. DeYoung
Mr. G. Maxwell
Mr. R. L. Prevatte

N. J. Chiangi - Manager
Quality Assurance/Quality Control
Harris Plant

8405070463 840424
PDR ADOCK 05000400
S PDR

110
IE27