

WESTERN UNION INCOMING

50-219

USAEC HQS GTWN

1970 JUL 2 PM 3 45

WU WSH

U.S. ATOMIC ENERGY COMMISSION
TOKYO UNIT

TLXA108 (52)PA109

WA P 004037 CG PD DOVER NJER 2 1130A EDT DR PETER A MORRIS

DIRECTOR DIVISION OF REACTOR

LICENSING US ATOMIC ENERGY COMMISSION WASHINGTON DC

THIS WILL CONFIRM MY TELEPHONE CONVERSATION WITH YOUR OFFICE
THIS MORNING THAT WE ARE PROCEEDING TO RESET THE OYSTER CREEK
ISOLATION CONDENSER TRIP SETTING FOR HIGH FLOW IN THE CONDENSATE
LINE IN A DIFFERENTIAL PRESSURE OF 27" OF WATER IN ADDITION
AN ADMINISTRATIVE PROCEDURE IS BEING ESTABLISHED TO ALERT OPERATIONS
PERSONNEL TO MANUALLY ACTUATE THE ISOLATION CONDENSER SYSTEM
IN THE EVENT THE SYSTEMS IS REQUIRED BUT HAS ISOLATED DUE TO
APPARENT HIGH FLOW IN THE CONDENSATE LINE ANOTHER TELEGRAM
WILL FOLLOW ADVISING THE ABOVE HAS BEEN COMPLETED

IVAN R FINROCK JR MANAGER NUCLEAR GENERATING STATIONS J
C P AND L. —

WU WSH 324*

USAEC HQS GTWN

IS/OR/Staff 7/13/70
Ernst
AB

WESTERN UNION INCOMING

U.S. ATOMIC ENERGY COMMISSION
MAIL & RECORDS SECTION

1970 JUL 2 PM 4 13

RECEIVED

COPY SENT REGION

JUL 7 1970

02316

2058

8305020068 710223
PDR ADOCK 05000219
PDR