

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

May 4, 1984

U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

ATTENTION: Mr. James R. Miller, Chief
Operating Reactors Branch #3

SUBJECT: Calvert Cliffs Nuclear Power Plant
Units No. 2, Docket No. 50-318
Telephone conference meeting between NRR, Operating Reactors
Assessment Branch representatives and BG&E to discuss proposed
License Amendments to the Unit 2 Auxiliary Feedwater System

REFERENCE: (a) BG&E Letter from A. E. Lundvall, Jr. to Mr. James R. Miller dated
April 9, 1984.

Gentlemen:

This transmittal serves to document the agreements made during a recent telephone conference meeting held on May 2, 1984, between BG&E and NRC representatives concerning the proposed License Amendments forwarded by Reference (a). As a result of these discussions, we understand that NRR plans to issue an expedited License Amendment for Unit 2 that would essentially reflect the proposed changes made in Reference (a) with one major exception. As discussed during the meeting, the exception involves changing the allowed out-of-service times for a motor driven and steam driven AFW pump from 14 days and 30 days, respectively, to 7 days for any AFW pump.

This change was negotiated to expedite the review and approval of Reference (a) in order to support the current Unit 2 outage time frame. We understand that NRR plans to continue their review in light of the new Technical Specification guidance issued in Generic Letter 83-37 and additional information we plan to submit in support of the out-of-service times proposed in Reference (a). Based on the results of this review and further negotiations, the Limiting Conditions for Operation of the AFW System Technical Specifications will be revised at a future date to reflect an appropriate and mutually agreeable out-of-service time that recognizes the specific design of the Calvert Cliffs facility.


8405080003 840504
PDR ADOCK 05000318
P PDR

Handwritten: Aool
1/10

Mr. J. R. Miller
May 4, 1984
Page 2

With regard to the potential impact we identified on the current Unit 2 outage, we appreciate the special consideration you have provided in resolving the issue at hand and we remain available to provide any information you may deem necessary to justify our previous request for amendments to the AFW System Technical Specifications.

Yours very truly,

A handwritten signature in dark ink, appearing to be "J. S. Latham", written over a horizontal line.

General Supervisor
Training and Technical Services

RED/LOW/sjb

cc: L. B. Russell
D. W. Latham
L. E. Salyards
B. S. Montgomery
W. C. Holston