


MGMATLT HSB

2-033923E232 08/20

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 08-20 0453P EDT

ZIP 30303



western union

Mailgram



US ATOMIC ENERGY COMMISSION REGION 2 DIRECTORATE OF REGULATORY OPERATION
S
230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

ON AUGUST 20 1974 WHILE UNIT 2 WAS IN COLD SHUTDOWN CONDITION ROUTINE
SURVEILLANCE TESTING FOUND SUPPRESSION CHAMBER TO DRYWELLER VACUUM
BREAKERS POSITION INDICATING LIGHTS ON FCV-64-28G AND FCV-64-28L
INOPERABLE. THE CHECK LIGHT ON FCV-64-28G AND THE RED AND GREEN
LIGHTS ON FCV-64-28L WERE INOPERABLE.

H J GREEN PLANT SUPERINTENDENT BROWN FERRY NUCLEAR PLANT

16:53 EDT

MGMATLT HSB

COPY SENT TO: PDR /
LPDR /
NSIC /
TIC /

8305040112 740830
PDR ADOCK 05000260
S PDR