

MGMATLT HSB  
2-010639E230 08/18/74  
ICS IPMBNGZ CSP  
2057298316 MGM TDBN ATHENS AL 100 08-18 0255P EDT  
ZIP 30303

 Mailgram  
western union



➤ US ATOMIC ENERGY COMMISSION  
REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST NW  
ATLANTA GA 30303

ON 8-14-74 WITH UNIT 2 REACTOR IN A SHUTDOWN CONDITION OUTBOARD  
MSIV 1-52 FAILED TO OPEN WHEN MANUALLYACTUATED PRELIMINARY INVESTIGATION  
SUGGEST BINDING WITHIN THE VALVE BODY FURTHER INVESTIGATION AND  
CORRECTIVE ACTION ARE IN PROGRESS. REACTOR IS IN A COLD SHUTDOWN  
CONDITION

H J GREEN BROWNSFERRY NUCLEAR PLANT ATHENS ALABAMA

14:55 EDT

MGMATLT HSB

COPY SENT TO: PDR ☒  
LPDR ☒  
NSIC ☐  
TIC ☐

8305040126 740906  
PDR ADOCK 05000260  
S PDR