

2-024113E226 08/14/74

ICS IPMBNGZ CSP

2057298316 MGM TDBM THENS AL 100 08-14 0232P

ZIP-30303

western union

Mailgram



US ATOMIC ENERGY COMMISSION, REGION II DIRECTORATE OF REGULATORY
OPERATIONS
230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

BFAO-50-259/7444T ON AUGUST 13 1974 DURING ROUTINE SURVEILLANCE
TESTING ON UNIT ONE RECIRCULATION JET PUMP RISER D/P SWITCH PDIS-68-17
WAS FOUND TO OPERATE OUTSIDE THE TECHNICAL SPECIFICATION SET POINT
OF GREATER THAN 0.5 BUT LESS THAN 1.5 PSID AS SPECIFIED IN TABLE
3.2.8 THE SWITCH OPERATED 2.0 PSID THE REACTOR WAS AT 1087MWE
H J GREEN BROWNS FERRY NUCLEAR PLANT

14:32 EDT

MGMATLT HSB

COPY SENT TO: PDR ☒
LPDR ☒
NSIC ☐
TIC ☐

8305040140 740823
PDR ADOCK 05000259
S PDR