

2-034179E225 08/13/74

ICS IPMBNGZ CSP

2057298316 MGM TDB ATHENS AL 100 08-13 0351P
ZIP

western union

Mailgram



US ATOMIC ENERGY COMMISSION
REGION 2 DIRECTORIC OF REGULATORY OPERATIONS 230 PEACHTREE ST NORTH
WEST
ATLANTA GA 30303

BFAO-50-260/746T ON AUGUST 13 1974 UNIT TWO HPCI INJECTION VALVE
OPERATOR FAILED DURING ROUTINE START UP TESTING RCIC FAILED TO
REACHED RATED FLOW DURING SUBSEQUENT REQUIRED SURVEILANCE TESTING
UNIT WAS AT RATED CONDITIONS AT APPROXIMATELY 5 PERCENT THERMAL
POWER AN ORDERLY SHUTDOWN AND PRESSURE REDUCTION AS REQUIRED BY
TECHNICAL SPECIFICATIONS IS IN PROGRESS
H J GREEN BROWNS FEIRY NUCLEAR PLANT

15:51 EDT

MGMATLT HSB

COPY SENT TO:

PDR ☒
LPDR ☒
NSIC ☐
TIC ☐

8305040169 740823
PDR ADDCK 05000260
S PDR

Handwritten: 50-260