

MGHATLT HSB  
2-029298E223 08/11/74

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 08-11 0731P EDT  
ZIP 30303



western union

Mailgram



U.S. ATOMIC ENERGY COMMISSION REGION 2 DIRECTOR OF REGULATORY OPERATIONS  
230 PEACHTREE ST NORTHWEST  
ATLANTA GA 30303

ON AUGUST 11 1974 UNIT TWO HPC1 EXHAUST LINE RUPTURE DISC FAILED  
CONCURRENT WITH HPC1 TURBINE START. REACTOR WAS AT RATED PRESSURE  
AT APPROXIMATELY 5 PERCENT THERMAL POWER HPC1 MANUAL START TEST  
WAS IN PROGRESS AS A PART OF THE STARTUP TEST PROGRAM  
H J GREEN BROWNS FERRY NUCLEAR PLANT

19131 EDT

MGHATLT HSB

COPY SENT TO: PDR ☒  
IPDR ☒  
NSIC ☐  
TIC ☐

8305040188 740821  
PDR ADOCK 05000260  
S PDR