

MGMATLT HSB  
2-016382E222 08/10/74  
ICS IPMBNGZ CSP  
2057298316 MGM TDBN ATHENS AL 100 08-10 0320P EDT  
ZIP 30303

western union

Mailgram



US ATOMIC ENERGY COMMISSION REGION 2 DIRECTORATE OF REGULATORY OPERATIONS  
230 PEACHTREE ST NORTHWEST  
ATLANTA GA 30303

ON AUGUST 10 1974 WHILE PERFORMING MANUAL START OF HPCI DURING  
START UP TESTING ON UNIT 2, HPCI STEAM SUPPLY ISOLATED AUTOMATICALLY  
BY HIGH STEAM FLOW SIGNAL THE REACTOR WAS OPERATING AT 800 PSIG  
IN THE HOT FUNCTIONAL PHASE OF THE START UP TEST PROGRAM  
H J GREEN SUPERINTENDENT BROWNS THEORY NUCLEAR PLANT

15120 EDT

MGMATLT HSB

COPY SENT TO: PDR ☒  
LPDR ☒  
NSIC ☐  
TIC ☐

8305040238 740820  
PDR ADOCK 05000260  
S PDR