

MGMATLT HSB  
2-045908E221 08/09/74

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 08-09 0450P EDT  
ZIP



western union

Mailgram



US ATOMIC ENERGY COMMISSION  
REGION II DIRECTORATE OF REGULATORY OPERATIONS PEACHTREE ST  
NORTHWEST  
ATLANTA GA 30303

ON AUGUST 9 1974 BY PERFORMING ROUTINE SURVEILANCE TESTING ON UNIT  
TWO RHR PUMP DISCHARGE PRESSURE SWITCH PS-74-19A WAS FOUND TO BE  
INOPERABLE THIS SWITCH IS A PART OF THE ONE OUT OF TWO LOGIC WHICH  
PROVIDES AN AUTOMATIC BLOW DOWN PERMISSIVE THE REDUNDANT SWITCH  
WAS OPERABLE THE REACTOR WAS OPERATING AT 800 PSIG IN THE HOT FUNCTIONAL  
PHASE OF THE START UP PROGRAM

H J GREEN BROWNS FERRY NUCLEAR PLANT

16151 EDT

MGMATLT HSB

COPY SENT TO: PDR ☒  
LPDR ☒  
NSIC ☐  
TIC ☐

8305040263 740819  
PDR ADCK 05000260  
S PDR