

MGMATLT HSB
2-030396E221 08/09/74
ICS IPMBNGZ CSP
2057298316 MGM TDBN ATHENS AL 100 08-09 0136P EDT
ZIP 30303

 Mailgram
western union



US ATOMIC ENERGY COMMISSION REGION II DIRECTORATE OF REGULATORY
OPERATION
230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

BFA0-50-260/742T ON AUGUST 8 74 A REVIEW OF START-UP TEST DATA
DISCLOSED THAT PDIS71-1ARCIC HIGH STEAM FLOW ISOLATION SWITCH WAS
INOPERABLE THE REDUNDANT PDIS71-1B WAS TESTED AND FOUND OPERABLE
THE UNIT WAS UNDERGOING HOT FUNCTIONAL START-UP TESTING AT 150PSIG
H J GREEN BROWNS FERRY NUCLEAR PLANT

13136 EDT

MGMATLT HSB

COPY SENT TO:

PDR ☒
LPDR ☒
NSIC ☐
TIC ☐

8305040277 740816
PDR ADDCK 05000260
S PDR