

MGMATLT HSB
2-016586E173 06/22/74
ICS IPMBNGZ CSP
2057298316 MGM TDBN ATHENS AL 100 06-22 0223P EDT
ZIP 30303

 Mailgram
western union



US ATOMIC ENERGY COMMISSION
REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST
NORTHWEST
ATLANTA GA 30303

BFAO 7442T FOLLOWING A REACTOR TRIP ON JUNE 21 1974 ADDITIONAL
ATTEMPT TO START HPCI MANUALLY WAS UNSUCCESSFUL HPCI DID START
ON THIRD ATTEMPT HPCI WAS NOT REQUIRED AND AUTO INITIATED SIGNAL
WAS NOT PRESENT

H J GREEN BROWNS FERRY NUCLEAR PLANT

14:24 EDT

MGMATLT HSB

COPY SENT TO:

PDR ☒
LPDR ☒
NSIC ☐
TIC ☐

8305040360 740701
PDR ADDCK 05000259
S PDR