



Telegram

341P EDT JUN 18 74 AA097

AAE190(1532)(2-028683E169)PD 06/18/74 1532

ICS IPMBNGZ CSP

DUPLICATE OF TELEPHONED TELEGRAM

2057298316 TDBN ATHENS AL 44 06-18 0332P EDT

PWS US ATOMIC ENERGY COMMISSION, FONE

REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST
NORTHWEST

ATLANTA GA 30303

BFAO-7441T AT 1120AM ON JUNE 18 1974 DURING QUARTERLY SURVEILLANCE
TESTING OF UNIT 1 CORE SPRAY SYSTEMS LOGIC RELAY 14A-K2B WAS
FOUND TO BE INOPERABLE THE RELAY WAS REPAIRED IMMEDIATELY
AND RETESTED SATISFACTORILY THE UNIT WAS OPERATING AT 100 PERCENT
POWER

H J GREEN BROWNN FERRY NUCLEAR PLANT

NNNN

*June 19 CB
of 109a mail*

*5264583
of 109a mail
18 1532P*

SF-1201 (RS-69)

COPY SENT TO: PDR ☒
LPDR ☒
NSIC ☐
TIC ☐

8305040384 740627
PDR ADOCK 05000259
S PDR