



# Telegram

KKXERP EDT JUN 14 74 AB240

AAD415(2155)(2-055006E165)PD 06/14/74 2155

ICS IPMMTZZ CSP

5264503  
DUPLICATE OF TELEPHONED TELEGRAM

S092342900 RELAY TDMT MOORESTOWN NJ 06-14 0955P EDT

PMS 2-036490E165 2057298316 TDBN ATHENS AL 31 06-14 0414P EDT

US ATOMIC ENERGY COMMISSION WUX REGION 2 DIRECTORATE OF REGULATORY  
OPERATIONS 230 PEACHTREE ST NORTHWEST WUX

ATLANTA GA 30303

BFA0-7440T RADWASTE BUILDING EXHAUST CONTINUOUS AIR MONITOR  
WAS OUT OF SERVICE FOR A PERIOD OF 1-1/2 HOURS ON 6-14-74 BUILDING  
SURVEYS INDICATE THERE WAS NO UNUSUAL RELEASE DURING THIS PERIOD

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

*June 15 CP  
of 10340 mailed*

SF-1201 (RS-69)

COPY SENT TO:

PDR ☒  
LPDR ☒  
NSIC ☐  
TIC ☐

8305040404 740621  
PDR ADOCK 05000259  
S PDR