



Telegram

526-1503
DUPLICATE OF TELEPHONED TELEGRAM

047A EDT JUN 11 74 AB048

A AAD089(1035)(2-011208E162)PD 06/11/74 1035

ICS IPMMIZZ CSP

6092342900 RELAY TDMT MOORESTOWN NJ 06-11 1035A EDT

PMS 2-032588E161 2057298316 TDBN DECATUR AL 34 06-10 0417P EDT

US ATOMIC ENERGY COMMISSION REGION 2 DIRECTORATE OF REGULATORY
OPERATION WUX 230 PEACHTREE ST NW

ATLANTA GA 30303

BFAO 7439T ON JUNE 9 1974 FOLLOWING A PLANNED REACTOR TRIP DIFFICULTY
WAS EXPERIENCED IN MANUALLY STARTING HPCI HPCI WAS NOT CALLED
UPON FOR AUTOMATIC START AND AFTER SEVERAL ATTEMPTS WAS SUCCESSFULLY
STARTED MANUALLY

H J GREEN BROWNSFERRY NUCLEAR PLANT

NNNN

11/20 1231p CB Mailed

SF-1201 (R5-69)

COPY SENT TO:

PDR ☒
LPDR ☒
NSIC ☒
TIC ☒

8305040431 740619
PDR ADOCK 05000259
S PDR