



Telegram

1023A EDT JUN 7 74 AC047

AAC096(1020)(2-009017E158)PD 06/07/74 1019

ICS IPMMTZZ CSP

Duplicate of telephoned telegram

6092342900 TDMI MOORESTOWN NJ 06-07 1019A EDT

PMS 2-006483E158 2057298316 TDBN DECATUR AL 43 06-07 0925A EDT

US ATOMIC ENERGY COMMISSION WUX REGION 2 DIRECTORATE OF REGULATORY
OPERATIONS 230 PEACHTREE ST NW

ATLANTA GA 30303

BFA0-7438T DURING START UP TESTING ON JUNE 6 1974 FCV-1-27 MAIN
STEAM LINE B OUTBOARD OSCILLATION VALVE CLOSED IN 1.7 SECONDS

THIS IS OUTSIDE THE 3-5 SECOND RANGE REQUIRED BY TECHNICAL SPECIFICATION
THE REACTOR WAS AT APPROXIMATELY 70 PERCENT THERMAL POWER

H J GREEN BROWNS FERRY NUCLEAR PLANT

CB

NNNN

7TH WL 1144A MAILED

ST-1201 (R5-69)

526-4503

COPY SENT TO:

PDR ☒

LPDR ☐

NSIC ☐

TIC ☐

8305040585 740614
PDR ADDOCK 05000259
S PDR