



Telegram

1033A EDT JUN 4 74 AC061 DUPLICATE OF TELEPHONED TELEGRAM

AAB103(1021)(2-009381E155)PD 06/04/74 1021

ICS IPMMTZZ CSP

6092342900 TDMT MOORESTOWN NJ 06-04 1021A EDT

PMS 2-016200E154 2057298316 TDBN ATHENS AL 47 06-03 1237P EDT

US ATOMIC ENERGY COMM WUX REGION 2 DIRECTORATE OF REGULATORY
OPERATION 230 PEACHTREE ST NW

ATLANTA GA 30303

BFA07437T ON JUNE 2 1974 DURING ROUTINE SURVEILLANCE TESTING
REACTOR WATER LEVEL SWITCH LIS-3-58B SWITCH #2 WAS FOUND TO
OPERATE OUTSIDE THE TECHNICAL SPECIFICATION SET POINT OF 378
FEET ABOVE VESSEL 0 THE REACTOR WAS IN THE START UP MODE TO
CONTINUE START UP TESTINGS

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

JUNE 4 CB
PJ 308P MAILED

526 4503

SF-1201 (R5-69)

COPY SENT TO: PDR ☒
LPDR ☒
NSIC ☐
TIC ☐

8305040640 740612
PDR ADOCK 05000259
S PDR