


2-016228E154 06/03/74

ICS IPMBNGZ CSP

western union

mailgram



2057298316 MGM TDB THENS AL 100 06-03 1237P T

ZIP 30303

U.S. ATOMIC ENERGY COMMISSION
REGION 2 DIRECTORATE OF REGULATORY OPERATION 230 PEACHTREE ST
NORTHWEST
ATLANTA GA 30303

BFA07437T ON JUNE 2 1974 DURING ROUTINE SURVEILLANCE TESTING
REACTOR WATER LEVEL SWITCH LIS-3-58B SWITCH #2 WAS FOUND TO
OPERATE OUTSIDE THE TECHNICAL SPECIFICATION SET POINT OF 378
FEET ABOVE VESSEL 0 THE REACTOR WAS IN THE START UP MODE TO
CONTINUE START UP TESTINGS

H J GREEN BROWNS FERRY NUCLEAR PLANT

12:37 EDT

MGMATLT HSB

8305040652 740612
PDR ADOCK 05000259
S PDR