

2-000229E147 05/27/74

ICS IPMBNGZ CSP

2057298316 MGM TDRM THENS AL 100 05-27 0023A

ZIP 30303

western union

Mailgram



US ATOMIC ENERGY COMMISSION

REGION TWO DIRECTORATE OF REGULATORY OPERATIONS 230 PEACH TREE  
ST NORTHWEST

ATLANTA GA 30303

BFA07435T AT 145PM 5-26-74 WITH UNIT AT APPROXIMATELY 37 PERCENT  
POWER HPCI ISOLATED ON HIGH STREAM FLOW DURING ROUTINE SURVEILLANCE  
TESTING SUBSEQUENT ATTEMPTS TO OPEN INNER HPCI STEAM LINE CONTAINMENT  
ISOLATION VALVE UNSUCCESSFUL

H J GREEN BROWNS FERRY NUCLEAR PLANT

06:15 EDT

MGMATLY HSB

8305040695 740605  
PDR ADDCK 05000259  
S PDR