


MGMATLT HSB

2-022350E142 05/22/74

ICS IPMRNGZ CSP

2057298316 MGM TDRN ATHENS AL 100 05-22 0138P EDT

ZIP 30303



western union

Mailgram



US ATOMIC ENERGY COMMISSION  
REGION 2 DIRECTORATE OF REGULATORY OPERATION 230 PEACH TREE  
ST NORTHWEST  
ATLANTA GA 30303

BFA0-7434T THE UNIT 1 HPCI INJECTION VALVE FCV-73-44 WAS DISCOVERED  
TO BE INOPERABLE AT APPROXIMATELY 515 PM 5-21-74 DUE TO A BURNED  
OUT MOTOR. THE MOTOR APPARENTLY FAILED AT APPROXIMATELY 215  
AM ON THE SAME DATE WHEN A 250 VOLT DC GROUND ACCURED WHICH  
WAS TRACED TO THIS VALVE THE UNIT WAS IN THE COLD SHUTDOWN CONDITION  
AT THE TIME.

H J GREEN BROWNS FERRY NUCLEAR PLANT

13138 EDT

MGMATLT HSB

8305040717 740530  
PDR ADOCK 05000259  
S PDR