

MGMATLT HSB

2-022158E142 05/22/74

ICS IPMBNGZ CSP

2057298316 MGM TDRN ATHENS AL 100 05-22 0134P EDT

ZIP 30303



western union

Mailgram



US ATOMIC ENERGY COMMISSION
REGION 2 DIRECTORATE OF REGULATORY OPERATION 230 PEACH TREE
ST NORTHWEST
ATLANTA GA 30303

BFA0-7433T ON MAY 21 74 AT 1045 AM WHILE CONDUCTING A ROUTINE
SERVALENCE TEST DAMPER FCV-64-44 FAILED TO OPEN THIS IS THE
REFUELING ZONE EXHAUST TO STANDBY GAS TREATMENT CROSSTIE DAMPER
THE REDUNDANT DAMPER FCV-64-45 WAS IMMEDIATELY PROVEN OPERABLE
AND WOULD HAVE BEEN AVAILABLE IN THE EVENT OF A SIGNAL FROM
THE REFUELING FLOOR UNIT 1 WAS IN THE COLD SHUTDOWN CONDITION
H J GREEN BROWNS FERRY NUCLEAR PLANT

13134 EDT

MGMATLT HSB

8305040725 740530
PDR ADDCK 05000259
S PDR